

## **Section B – Grading notes have been updated.**

On Sheet B7, the first sentence of the eighth paragraph in the PROCEDURES FOR DETERMINING UNCLASSIFIED EXCAVATION note was revised to provide clarification on the payment for Salvaged Asphalt Mix and Granular Base Material.

On Sheet B18, the reference to "Type B Frame and Grate Assembly" was changed to "Type B Frame and Grate" in the second paragraph of the second DROP INLETS note.

On Sheet B18, the "Total Type B Frame and Grate Assembly" was changed to "Total Type B Frame and Grate" in the TABLE OF DROP INLETS AND QUANTITIES note.

On Sheet B19, the colored concrete product was revised from "Color #417 Red" to "Color #417 Brick Red" in the COLORED CONCRETE FOR XXXXX and COLORED AND PATTERNED CONCRETE FOR XXXXX notes.

On Sheet B25, the HIGH TENSION CABLE GUARDRAIL note was revised. Some of the changes to the note include:

- The High Tension Cable Guardrail will meet the requirements of the Manual for Assessing Safety Hardware (MASH) and two systems can be used.
- The maximum dynamic deflection changed from 8'-0" to 10'-0" and the maximum post spacing changed from 16'-0" to 10'-6".
- The galvanized steel sleeve will be designed for a minimum frost depth of 42".
- The high tension cable guardrail will be measured and paid to the effective length or length of need.

On Sheet B25, HIGH TENSION CABLE GUARDRAIL ANCHOR ASSEMBLY note was revised to include two approved assemblies.

Section B – Grading Standard Note file may be downloaded from [here](#).