

Method of Test for Air Entraining Admixtures for Concrete

1. Scope:

This test is for materials proposed for use as air entraining admixtures.

2. Apparatus:

As specified in AASHTO T 157.

3. Procedure:

3.1 The procedure shall be the same as specified in AASHTO T 157 with the following exceptions:

- A. Design of concrete mixtures for standards shall be those shown on job mix design sheets without entrained air.
- B. Freezing and thawing and length change tests are to be omitted from routine control work.
- C. For control purposes, 7 day strength shall be considered sufficient.

4. Report:

As required by AASHTO T 157.

5. References:

AASHTO T 157