

EQUIPMENT CALIBRATION, STANDARDIZATION OR CHECK RECORD

Original 12/96, Revised 3/2/98, 3/11, 7/14

PROCEDURE #7

Date: _____ Standardized by: _____

Equipment: UNIT WEIGHT MEASURE T 19, T 121, SD 205, SD 403, SD 411

Previous standardized date: _____ Next due: _____ Frequency: 12 Months Max

Inspection equipment and serial number:

Scale, readable to 0.1 lb #: _____ Glass plate to cover measure _____

Caliper readable to 0.001" #: _____ 12' Tape measure #: _____

Feeler gage 0.01" thick #: _____ 15" Straightedge#: _____

Serial Number						
Capacity of measure						
Inner diameter						
Inside height						
Rim smooth & plane (Y/N)						
Thickness of bottom						
Thickness of rim						
Length and diameter of rod						
Action (Repair/Replace/None)						

STANDARDIZATION OF MEASURE USING WATER AT A KNOWN TEMPERATURE

Size of measure	(A) Weight of empty measure and glass plate	(B) Weight of measure filled with water, and glass plate	(C) Weight of water to fill measure	Volume in cu. ft	Temp of water
1/10"					
1/4"					
1/3"					
1/2"					
1"					

$$\frac{\text{MASS OF WATER}}{\text{(UNIT WT. OF WATER)}} = \text{CU. FT.}$$

$$\frac{\text{UNIT WT OF WATER}}{\text{MASS OF WATER}} = \text{FACTOR}$$

Tamping rod have a 16 mm diameter? (yes / no)

24" long? (yes / no)