## EQUIPMENT CALIBRATION, STANDARDIZATION OR CHECK RECORD

				Revised 12/96, 5/11
				PROCEDURE #38
Date:			Checked	by:
Equipment: SLUMP CONE				T 119, SD 404
Previous check date:	Next due:			Frequency: Region - 12 Mo.
				Field Lab/Area - 12 Mo.
Inspection equipment and serial number:				
Caliper readable to 0.001" (0.025 mm) #:		or	Measurin	g tape readable to <sup>1</sup> / <sub>16</sub> " #:

Serial Number	Base Diameter	Wall Thickness	Top Diameter	Height of mold	Action
	8 ± 1/8"	Min. 0.045" (1.14 mm)	4 ± 1/8"	12 ± 1/8"	Repair/Replace None